

ALABAMA DEPARTMENT OF HUMAN RESOURCES
CHILD CARE PERFORMANCE STANDARDS DEFICIENCY REPORT

SECTION A- IDENTIFYING INFORMATION

Facility Name: FOCUS POINT EDUCATION ACADEMY	Type of Facility : Center [X] Day [X] OST [] Night [] Family [] University [] Group []	Date of Visit: 8/20/2026
Facility Address: 13074 EDNA BRAKE LUCAS DR, MONTGOMERY, AL 36117, Montgomery	Licensee: FOCUS POINT EDUCATION ACADEMY	Telephone #: (334) 270-9571
Ages: 6 Weeks to 15 Years	Director (if applicable): TANEKI DELAINE MAYES	Capacity: 86 / NA Day Night

SECTION B - DEFICIENCY INFORMATION

<u>Performance Standard Deficiency</u> HAZARDS MUST BE CORRECTED IMMEDIATELY*	Date Corrected by Licensee
Deficiency Summary	
Failed - Outdoor play area and equipment are free of apparent hazardous conditions, Inspection Form Comments: Swing is broken on the 2 1/2 and up playground.	8/23/2026
Failed - Fence or wall free of sharp edges, Inspection Form Comments: Fence is detached at the bottom and has sharp edges.	8/25/2026
Failed - Shade and sun areas provided, Inspection Form Comments: no shade	8/25/2026
Failed - One handwashing sink with warm running water soap paper towels in each room where children are diapered, Inspection Form Comments: Sink in the 18 month- 2 1/2 year classroom is not working.	8/25/2026
Failed - Heating/air conditioning provided, Inspection Form Comments: AC is not working in several areas of the facility.	8/21/2026
Failed - Temperature between 68-82 degrees, Inspection Form Comments: Lunchroom area is 84 degrees.	8/21/2026
Failed - Stairways have hand-railings in child's reach, Inspection Form Comments: Handrail in the lunch room.	8/25/2026
Failed - Barriers around heaters, radiators, fans, Inspection Form Comments: Fan does not have a barrier in the nap room.	8/25/2026
Failed - Vending machines prohibited in areas used by children, Inspection Form	8/27/2026

Comments: There is a vending machine in the front entry of the facility.

Failed - By August 1, 2022, director/all teachers/substitutes/all service staff must be enrolled in the Alabama Pathway's Professional Development Registry, Inspection Form 8/26/2026

Comments: Director is not registered in Pathways.

Failed - Vehicle safety check done annually, signed by certified mechanic, dated, and filed in center, Inspection Form 8/27/2026

Comments: Expired

Failed - Medical, Staff Checklist 8/24/2026

Comments: Expired

Failed - Medical, Staff Checklist 8/24/2026

Comments: Expired

INSTRUCTIONS TO LICENSEE: Column 2, Date Corrected by Licensee, is to be completed by the facility representative after each deficiency is corrected. The facility representative must put the date of correction and his/her initials in Column 2. This form must be returned to the Department of Human Resources on or before _____^x_____, as verification that deficiencies have been corrected.

NOTICE: Any misleading or any false statements or reports made to the Department and/or failure to correct the listed deficiencies can be the basis for adverse action. None of these requirements are to be interpreted to allow anyone to operate in violation of Performance Standards. A facility licensed by the Department must always meet Performance Standards applicable to that facility. It is the responsibility of the licensee to operate in compliance with Performance Standards.

Signature of Facility Representative

Date

JESSICA VICE

09/22/26

Signature of DHR Licensing Representative

Date

COPIES TO: _____